



**NOTE:**  
TAPS IN STAGGERED CONFIGURATION  
AT 10 O'CLOCK AND 2 O'CLOCK.

**SECTION A-A**

**NOTES:**

1. SANITARY SEWER SERVICE TAPS SHALL BE LOCATED ON THE MAIN AT THE 2 O'CLOCK OR 10 O'CLOCK POSITION.
2. THE MINIMUM DISTANCE BETWEEN ANY TWO CONSECUTIVE FITTINGS SHALL BE 3 FEET, MEASURED BETWEEN FITTING CENTERLINES.
3. SANITARY SEWER SERVICE TAPS SHALL NOT BE MADE WITHIN 3 FEET OF A PIPE JOINT, OR 5 FEET FROM EDGE OF MANHOLE BASE.
4. A MAXIMUM OF FOUR SERVICE TAPS ARE ALLOWED PER 20 FOOT LENGTH OF PIPE.
5. ALL SANITARY SEWER TAPS SHALL USE "WYE" STYLE FITTINGS. TEES ARE NOT ALLOWED.

<b>REVISED</b>		 <b>Southgate</b> <small>WATER &amp; SANITATION DISTRICTS</small>	SCALE
BY	DATE		NOT TO SCALE
		<b>PVC PIPE SERVICE CONNECTION TO NEW CONSTRUCTION</b>	ISSUE DATE
			FEBRUARY 2016
			SHEET <b>1 OF 1</b> DRAWING NO. <b>SS-13</b>