



NOTES:

1. SANITARY SEWER SERVICE TAPS SHALL BE LOCATED ON THE MAIN AT THE 2 O'CLOCK OR 10 O'CLOCK POSITION.
2. THE MINIMUM DISTANCE BETWEEN ANY TWO CONSECUTIVE FITTINGS SHALL BE 3 FEET, MEASURED BETWEEN FITTING CENTERLINES.
3. SANITARY SEWER SERVICE TAPS SHALL NOT BE MADE WITHIN 5-FEET OF A PIPE JOINT, OR EDGE OF MANHOLE.
4. A MAXIMUM OF FOUR SERVICE TAPS IS ALLOWED PER 20 FOOT LENGTH OF PIPE.
5. TAPPING OF EXISTING PIPE REQUIRES A LONG BODY STYLE WYE SADDLE WITH TWO STAINLESS STEEL STRAPS. THE CORING METHOD SHALL BE APPROVED BY THE DISTRICT, PRIOR TO CONSTRUCTION. THE "WYE" SADDLE SHALL BE FURNISHED WITH A RUBBER GASKET AND THE SADDLE SHALL BE SOLVENT WELDED TO THE PIPE. "TEE" STYLE FITTINGS ARE NOT PERMITTED EXCEPT BY WRITTEN PERMISSION OF THE DISTRICT.
6. CARE SHALL BE TAKEN WHEN EXCAVATING AND COMPACTING AROUND EXISTING LINES. SHOULD A LINE BE BROKEN, THE DISTRICT ENGINEER SHALL BE NOTIFIED IMMEDIATELY AND COORDINATE REPAIR PROCEDURES WITH THE CONTRACTOR.

REVISED		 Southgate WATER & SANITATION DISTRICTS	SCALE
BY	DATE		NOT TO SCALE
		SERVICE CONNECTIONS TO EXISTING CONSTRUCTION	ISSUE DATE
			FEBRUARY 2016
			SHEET 1 OF 1 DRAWING NO. SS-14